

REPORT OF INVESTIGATIVE ACTIVITY

1. DATE OF INVESTIGATIVE ACTIVITY 13 Feb 04	2. PLACE AFOSI Detachment 309, 223 Cody Ave Ste 1, Hurlburt Field, FL 32544-5310	3. ACTIVITY NUMBER 27880040500706
---	---	---

4. REMARKS

Review of: Florida Department of Environmental Protection Violations issued against Aztec Environmental, Inc
Date of Review: 13 Feb 04
Reviewer(s): [REDACTED] AFOSI DET 309

On 18 Feb 04, a review of Florida Department of Environmental Protection (FDEP) violations issued against Aztec Environmental, Inc (AZTEC) was performed (TAB A). In all projects, FDEP closed the violation without enforcement. However, the Bldg 90333, Hurlburt Field violations were still open and subject to FDEP enforcement. The following is a synopsis of the review:

Project Location	Project Date	Violation
Escambia Juvenile Justice Center	23 Mar 00	Failure to mark load out vehicle; not wetting roofing
Sun Plaza Shopping Center	23 May 00	Worker certificates not on site
University of West Florida	11 Jul 00	Wrong generator labels
Lynn Haven Elementary School	22 May 0	No notes in database
Escambia High School	19 Jun 01	Improper floor mastic removal
Brentwood Middle School	28 May 02	Regulated Asbestos Containing Material (RACM) bags in load out without generator labels; no warning signs on bldg
Howard Johnson	10 Oct 02	Used poly in bathroom tubs; RACM left on lights; dry RACM swept up
Beachwalk Motel	10 Oct 02	RACM left on ceilings; bags with contaminated material left in bathrooms; poly left on walls
Hurlburt Field Bldg 90333	23 Jul 03	Dry removal, not wetting, improper bagging, waste containers not labeled
Hurlburt Field Bldg 90333	25 Jul 03	Disposition of load out not known-later determined to be taken to C&D landfill

b6
b7c

5. CONDUCTED BY
[REDACTED]

THIS DOCUMENT CONTAINS NEITHER RECOMMENDATIONS NOR CONCLUSIONS OF AFOSI. IT IS THE PROPERTY OF THE AFOSI AND IS LOANED TO YOUR AGENCY; THIS DOCUMENT IS NOT TO BE RELEASED OUTSIDE YOUR AGENCY.