

Ferrigan, Chris

From: Sfiropoulos, John
Sent: Monday, October 20, 2008 11:30 AM
To: Ferrigan, Chris
Subject: FW: email on cross connections

Christine,
As requested, please see correspondence below, specifically in yellow.
Thanks,
John

From: Darrel_Graziani@doh.state.fl.us [mailto:Darrel_Graziani@doh.state.fl.us]
Sent: Monday, September 08, 2008 4:14 PM
To: Helfrich, Chris; Jose.Calas@dep.state.fl.us
Cc: Linda.Brien@dep.state.fl.us; Sfiropoulos, John
Subject: RE: Cross Connection

Sounds good to me.....and I think that is the basic inspection program that others are following.

Darrel J. Graziani, P.E.
Environmental Administrator - Bureau of Water Programs
Division of Environmental Health & Engineering
Palm Beach County Health Department
Phone 561-355-3070, ext. 1151

From: Helfrich, Chris [mailto:CHelfrich@ci.boca-raton.fl.us]
Sent: Monday, September 08, 2008 3:06 PM
To: Graziani, Darrel J; Calas, Jose
Cc: Linda.Brien@dep.state.fl.us; Sfiropoulos, John
Subject: RE: Cross Connection

Darrel

What is your basic inspection program?

Although we do not have a basic inspection program our program is enhanced, I would say that a basic inspection program for customers would be an inspection "drive-by" of the property to see if anything appears to be OK.

I would agree that an owner (residential or non-residential) that utilizes an RPZ that is tested on an annual basis would provide a "higher level" of protection than the dual checks, therefore a basic or enhanced inspection would not be required.

Thanks for your assistance
Chris Helfrich
Director Utility Services
City of Boca Raton

From: Darrel_Graziani@doh.state.fl.us [mailto:Darrel_Graziani@doh.state.fl.us]
Sent: Monday, September 08, 2008 8:55 AM
To: Helfrich, Chris; Jose.Calas@dep.state.fl.us
Cc: Linda.Brien@dep.state.fl.us; Sfiropoulos, John

10/24/2008