

**Non-Acute Maximum Contaminant Level (MCL) Violations for Total Coliform Bacteria  
at Missouri State Park Water Systems 2004 to 2011**

Water System Name	PWS ID #	Months of Violation <sup>1</sup>	Permanent Disinfection <sup>2</sup>	Chlorine Residual with Recent Results <sup>3</sup>
Big Oak Tree State Park	MO4121445	July 2004 September 2004 (Acute MCL violation for <i>E. coli</i> also in September 2004)	System inactive	Not applicable
Cuivre River State Park - Camp Derricotte	MO6120055	July 2011 August 2011 September 2011 (Acute MCL violation for <i>E. coli</i> also in September 2011) April 2012 May 2012	Not listed <sup>4</sup>	Yes, all but one sample collected since May 14, 2012 shows chlorine residual present.
Cuivre River State Park - Camp Sherwood	MO6122659	July 2011 September 2011 August 2012	No	No
Cuivre River State Park - Picnic Shelter	MO6122660	September 2005 October 2007	No	No
Graham Cave State Park - Campground	MO6120155	June 2004 August 2004	Yes	Some
Graham Cave State Park Office	MO6122671	October 2007 July 2009	Yes	Some
Harry S Truman State Park Marina	MO1122648	July 2005 August 2005 September 2005	Yes	Yes
Harry S Truman State Park Office	MO3120156	June 2007 August 2012	No	No
Hawn State Park	MO4120067	April 2011	Yes	Some
Knob Noster State Park - Campground	MO1120159	June 2004	Yes	Yes
Lake of the Ozarks State Park	MO3120160	February 2004	System inactive	Not applicable
Lake of the Ozarks State Park Outpost	MO5122670	September 2010	Yes	Yes
St. Francois State Park	MO4120167	June 2010 (Acute MCL violation for <i>E. coli</i> also in June 2010)	Yes	Yes
Washington State Park	MO6120173	October 2005 November 2007 November 2008 June 2010 November 2011	Yes	Some

<sup>1</sup>Source: DNR Annual Compliance Report for that year, except for 2012 violations with source as DNR's Drinking Water Watch. MCL violations at state park water systems with first violation in 2012 not captured.

<sup>2</sup>Source: Census of Missouri Public Water Systems 2013, System Treatment Processes section.

<sup>3</sup>Source: DNR's Drinking Water Watch.

<sup>4</sup>No treatment listed in 2013 Census, but all prior censuses posted on line state "HYPOCHLORINATION-POST".