

Table 3. Caulk Sample Results from ENVIRON's Investigation
 Malibu High School and Juan Caballero Elementary School
 Malibu, California

Building	Placard Room ID	Floor Plan Room ID	Room Description	Gap ID	Caulk Sample ID	Caulk Sample Length (cm)	Caulk Sample Mass (g)	Atorol Results (mg/kg)	Figure
MHS	E (000, Blue Shark)	3	Classroom	3-4	022815-MHS-B000-R3-L4-C1	44	14.5	1,800 J	2
		7	Classroom	7-1	022815-MHS-B000-R3-L10-C1	48	7.0	1,800 J	
		505	Art classroom	7-2	022815-MHS-B000-R7-L1-C1	35	3.5	330	3
I (400, Leopard Shark)	401	404N	Art classroom	505-1	022815-MHS-B500-R505-L1-C1	39	3.2	1,800	4
		401	Classroom	401-1	022815-MHS-B400-R401-L1-C1	88	5.8	220,000 J	
J (700, Old Gymnasium)	704	117	Faculty office	704-2	022815-MHS-B700-R704-L2-C1	74	3.5	4,500	6
		115A	Vestibule to 117	704-5	022815-MHS-B700-R704-L5-C1	7	3.4	1,800 J	
		704 Hall	704 Hallway Interior - 1	704-5	022815-MHS-B700-R704-L5-C2	6	3.6	1,500	
JCES	R18	18	PTA room	18-1	022815-JCES-BF-R18-L1-C1	57	2.2	290,000	10
				18-2	022815-JCES-BF-R18-L1-C2	40.5	2.1	270,000	
				19-1	022815-JCES-BF-R19-L1-C1	45	3.4	220,000	
				19-1	022815-JCES-BF-R19-L1-C1	65	3.2	390,000	
				19-2	022815-JCES-BF-R19-L1-C2	88	6.3	570,000	
				19-2	022815-JCES-BF-R19-L2-C1	75	8.6	550,000	
				22-6	022815-JCES-BF-R22-L6-C1	68	3.7	280,000	
				22-6	022815-JCES-BF-R22-L6-C2	49	3.2	470,000	
				22-7	022815-JCES-BF-R22-L7-C1	30	1.3	220,000	
				23-1	022815-JCES-BF-R23-L1-C1	62.5	3.6	130,000	
				23-1	022815-JCES-BF-R23-L1-C2	79	4.8	350,000	
				23-2	022815-JCES-BF-R23-L2-C1	5	1.3	440,000	
23-3	022815-JCES-BF-R23-L3-C1	45	3.3	280,000					
23-3	022815-JCES-BF-R23-L3-C1	66	2.7	180,000					

NOTE:

- Analytical report (15030351) was provided by the laboratory, ALS Environmental. Samples were analyzed by USEPA Method 8082.
- DVR (23878 - Level IV validation) was provided by LDC. The %R for the laboratory control samples were slightly higher than the QC limits of 50-130% affecting all TCL compounds, which were detected (J qualified).
- All yellow highlighted cells with bold text have total PCB concentrations exceeding 50 parts per million (ppm), which is defined and regulated as an "unauthorized use" under the United States Environmental Protection Agency (USEPA) Toxic Substances Control Act (TSCA) 40 CFR 761.

Abbreviations:

- cm = centimeters
- g = grams
- ID = identification
- J = Indicates an estimated value
- JCES = Juan Caballero Elementary School
- mg/kg = milligrams per kilogram
- MHS = Malibu High School
- NA = not applicable, not identified
- ppm = parts per million
- PTA = parent teacher association
- QC = quality control
- TCL = target compound list
- TSCA = Toxic Substances Control Act
- USEPA = United States Environmental Protection Agency