

Fitch, Jon

From: Kator, Martin
Sent: Tuesday, May 22, 2012 9:28 AM
To: Gregory, Eric
Cc: Fitch, Jon; Files, Dan; Purcell, Kris
Subject: Water Tank Inspectors

Use the link below to search for water tank inspectors in the state. A good tank inspection and cleaning should cost between \$600 - \$1200. As we discussed, I recommend starting the repair process of the Camp Derricotte water tank by having a thorough cleaning & inspection. DEQ suggests having tanks inspected every five years. I do not know when this tank was last inspected. The tank inspector will provide you with a report following the inspection detailing their findings. This report should provide you with the information you will need to determine extent of the damage and if a repair is necessary. Be sure in your bid request to require that they provide a report with photos and recommendations.

With DEQ closely watching this site, this would be a positive step for us. You will be able to kill two birds with one stone on this one.

Here is the link: <http://moruralwater.org/associates/>

Select the "Tank Restoration and Inspections" category in the drop down box to find a list of inspectors.

Martin Kator
Environmental Specialist IV
Missouri Department of Natural Resources
Division of State Parks
Office# 573-522-6380
Fax# 573-526-7716
martin.kator@dnr.mo.gov



Visit Missouri State Parks at
www.mostateparks.com

From: Gregory, Eric
Sent: Tuesday, May 22, 2012 8:39 AM
To: Kator, Martin
Subject: FW: Water Tower pics

From: Gregory, Eric
Sent: Monday, April 30, 2012 4:06 PM
To: Druce, Rodney
Subject: Water Tower pics

Eric Gregory
Missouri State Parks

Kator, Martin

From: Kator, Martin
Sent: Wednesday, June 13, 2012 8:02 AM
To: Gregory, Eric
Subject: RE: Water Tank Survey Follow-up

Morning Eric,

Yes I hope to have a statewide contract for all tanks to be inspected on a five year cycle in place before the end of the recreational season. If the Derricotte tank is holding up then I agree that it would be advantageous to wait for the statewide inspector to come out this fall/winter as it should be less expensive. The only concern I have is with the current state of the system and the rash of bad samples. If the chlorine system, after everything is up and running the way it should, works and our bacteriological samples consistently come back good, then I have no problem waiting for the inspection...But if the sample continue to come back bad we will need to continue to take strives to address any and all possible concerns. This would likely require having the tank inspected before the end of the recreational season along with a thorough inspection of the distribution system.

We will continue to keep in touch. How are the kayak rentals coming?

Thanks,

Martin Kator
Environmental Specialist IV
Missouri Department of Natural Resources Division of State Parks Office# 573-522-6380 Fax# 573-526-7716
martin.kator@dnr.mo.gov

Visit Missouri State Parks at:
www.mostateparks.com

From: Gregory, Eric
Sent: Wednesday, June 13, 2012 7:36 AM
To: Kator, Martin
Subject: RE: Water Tank Survey Follow-up

Martin,

I have held off on bidding the water tower inspection in Derricotte until we have the pump room control panel fixed. Flynn Drilling is supposed to be here today or tomorrow to complete the repairs. The water tower did stop leaking, but I think it is safe to assume that it is a matter of time before it starts again.

Should I proceed with the inspection? It sounds like you are doing something statewide now.

Please let me know at your convenience.

Thanks,

Eric Gregory
Missouri State Parks
Natural Resource Manager
Cuivre River State Park
678 State Route 147

Kator, Martin

From: Gregory, Eric
Sent: Wednesday, September 11, 2013 2:17 PM
To: Kator, Martin
Subject: FW: Water tower inspections

fyi

-----Original Message-----

From: Mueller, Paul
Sent: Wednesday, September 11, 2013 2:02 PM
To: Cuivre River State Park
Cc: Gregory, Eric
Subject: RE: Water tower inspections

I have nothing except DNR external comments during water system inspections.

Paul Mueller
Lincoln County Satellite Office
MO-DNR
O# 636-528-4779
F# 636-528-8362
C# 314-803-7163
P Please consider the environment before printing this email.

-----Original Message-----

From: Cuivre River State Park
Sent: Wednesday, September 11, 2013 12:44 PM
To: Mueller, Paul
Subject: Water tower inspections

Paul,

Not sure if Eric has contacted you about this yet or not. Do you know the last time that our water towers were inspected (inside and out)? If yes, do you have any paperwork on that?

Thanks,

Stephanie

Missouri State Parks
Cuivre River State Park
678 State Route 147
Troy, MO 63379
636-528-7247
636-528-5817 (fax)
www.mostateparks.com